

Referral Comments

<i>Type of Referral</i>	<i>Responses</i>
Internal	
Engineering	No objection subject to conditions including the owner entering into an agreement with Council pursuant to <i>Section 173 of the Planning and Environmental Act 1987</i> for the provision of on-site detention for all the subdivided lots, all proposed vehicle crossing must be constructed to a heavy duty standard in accordance with Council's Standard Drawings and storm water must not be discharged from the site other than by means of an underground pipe drain discharged to a legal point of discharge.
External	
Nil	Nil