



**NOTES:**

1. REINFORCEMENT MESH TO BE CENTRALLY PLACED THROUGHOUT CROSSING. MINIMUM 50MM COVER AT ALL TIMES. APPROVED BAR CHAIRS MUST BE USED FOR PROPER PLACEMENT OF REINFORCEMENT. JOINTS TO OVERLAP ONE FULL PATTERN AS PER AS 3600 & AS2870.1.
2. NATURE STRIPS TO BE MADE FLUSH WITH NEW CONCRETE WORKS AND SHALL BE OF APPROVED TOP SOIL AND SEED.
3. CONCRETE STRENGTH TO BE 25 MPA AT 28 DAYS.
4. FOR A DOUBLE OR TRIPLE PARKING BAY, WEAKENED PLANE JOINT TO BE PROVIDED AT 6M INTERVALS.
5. CLASS 3 CRUSHED CONCRETE CAN BE USED AS BEDDING MATERIAL IN PLACE OF CLASS 3 CRUSHED ROCK

17/1/2017 2:04:59 PM

| ISSUE | APP'D | DATE  | AMENDMENT                   |
|-------|-------|-------|-----------------------------|
| E     |       |       |                             |
| D     |       |       |                             |
| C     |       |       |                             |
| B     | M.H.  | 05/16 | REVIEWED AND UPDATED DESIGN |
| A     | V.C.D | 01/09 | INITIAL DESIGN              |

| GENERAL NOTES |  |
|---------------|--|
|               |  |



|         |              |
|---------|--------------|
| DESIGN  | L.SHE        |
| DRAWN   | L.SHE        |
| CHECKED | M.HUTCHINSON |
| DATE    | APRIL 2016   |

|         |                            |
|---------|----------------------------|
| PROJECT | STANDARD DRAWING - MCC 204 |
| DETAILS | INDENTED PARKING BAY       |

|   |          |
|---|----------|
| N.T.S.  |          |
| SHEET 1 OF 1                                    | PAPER A4 |
| DRAWING No.                                     | REV B    |
| FILE NAME<br>MCC 204 - INDENTED PARKING BAY.DWG |          |